

## **VARIOUS ITEMS THAT MAY BE CHECKED ON YOUR INSPECTION VISIT**

### **FIRE DEPARTMENT ACCESS:**

Fire lanes maintained?  
Fire hydrants accessible? (3 ft. clear)  
Fire Department Connection accessible?  
Address visible from street?

### **FIRE PROTECTION SYSTEMS:**

Do all fire protection systems have power?  
Are all valves open and appear in good condition?  
Inspected in the preceding 12 months with blue tag to ensure operability of the system?  
Kitchen hoods checked, cleaned, and maintained?

### **MEANS OF EGRESS:**

Are exit lights properly illuminated?  
Are all exits clear and unobstructed?  
Do all exit doors function properly?

### **HAZARDOUS MATERIALS:**

Are all hazardous processes/hazardous storage areas properly maintained?

### **COMBUSTIBLE STORAGE:**

Are all mechanical, electrical, and machine rooms accessible and maintained without combustible storage?

### **ELECTRICAL EQUIPMENT:**

3 ft. clearance maintained in front of panel boards?  
Extension cords as permanent wiring.

### **FIRE EXTINGUISHERS:**

Are they maintained?  
Minimum one (2A 10 BC) for every 3000 square feet.