

Elevator Recall and Elevator Shaft Protection

In order to match the new state elevator codes, we will no longer place sprinkler heads in the elevator shaft for passenger elevators and there will not be any detection devices in the elevator shaft.

Recall and detection requirements for the elevator equipment room and elevator lobbies will remain the same as we have been doing.